



# ESTES VALLEY FIRE PROTECTION DISTRICT

PREVENT PREPARE PERFORM

## EVFPD Target Hazard Assessment Form (Page 1 of 2)

Building Address: \_\_\_\_\_ OCC ID: \_\_\_\_\_

Property/Business Name: \_\_\_\_\_

Person Making Assessment: \_\_\_\_\_

Date: \_\_\_\_\_ Initial or Update? \_\_\_\_\_

Risk Assessment Rating: \_\_\_\_\_ (Low 13-20; Medium 21-29; High 30+)

Multi-family w/out automatic fire sprinklers = High

Life Hazard \_\_\_\_\_ Score \_\_\_\_\_  
High- 100 or more occupants 3  
Medium- 25-99 occupants 2  
Low- Less than 25 occupants 1  
*Multiply value by 3 if sleeping units are present*

Self-Rescue Capability \_\_\_\_\_ Score \_\_\_\_\_  
High- 50% or more of occupants cannot self-rescue 3  
Medium- 25%-49% of occupants cannot self-rescue 2  
Low- 24% or less of occupants cannot self-rescue 1

Community Impact \_\_\_\_\_ Score \_\_\_\_\_  
High Impact- irreplaceable/historical/critical 3  
(hospital, utility, government, mass evacuation, etc)  
Medium Impact- casualty potential, job loss, tax, food supply 2  
Low Impact- minor community impact 1

Hazard Index \_\_\_\_\_ Score \_\_\_\_\_  
High- Complex, multiple, industrial, special 3  
Medium- Simple, moderate, business 2  
Low- Limited, common residential 1

Water Supply \_\_\_\_\_ Score \_\_\_\_\_  
High - Zero Hydrants within 500' or Water shuttle ops required 3  
Medium - One Hydrant within 500' 2  
Low - Two or more Hydrants within 500' 1

Building Usage \_\_\_\_\_ Score \_\_\_\_\_  
Industrial, High life hazard, large business 3  
Residential (apartment, motel, dorm, etc) 2  
Office, small business 1

*Serving the Residents and Visitors of the Estes Valley with Superior Fire and Safety Services*



**ESTES VALLEY FIRE PROTECTION DISTRICT**  
**PREVENT PREPARE PERFORM**

**EVFPD Target Hazard Assessment Form (Page 2 of 2)**

Building Construction \_\_\_\_\_ Score \_\_\_\_\_  
Combustible 3  
Limited Combustibility 2  
Non-Combustible 1  
*Multiply value by 3 if lightweight/ wood truss construction*

Number of Stories \_\_\_\_\_ Score \_\_\_\_\_  
3 or more stories 3  
2 stories 2  
1 story 1

Square Footage \_\_\_\_\_ Score \_\_\_\_\_  
15,000 SF or greater 3  
7,501-14,999 SF 2  
7,500 or less 1

Sprinkler/Suppression System \_\_\_\_\_ Score \_\_\_\_\_  
No system 3  
Full system 1  
*If a partial system is present, score as no system and log the details on the preplan sheet so they are entered into preplan system*

Access \_\_\_\_\_ Score \_\_\_\_\_  
High - 1 or fewer apparatus can get within 50' of building 3  
Medium - 2 to 3 apparatus can get within 50' of building 2  
Low - 3 or more apparatus can get within 50' of building 1

Hazardous Materials (add Tier II, 704, and Special) \_\_\_\_\_ Score \_\_\_\_\_  
Tier II Reporting 3  
No Reporting 0

NFPA 704 Ranking \_\_\_\_\_ Score \_\_\_\_\_  
Health, Fire, Radioactive is 3 or 4 3  
H, F, R is 2 2  
H, F, R is 1 or less 1  
*If Special = W, add 3 to score*

Officer Overall Impression \_\_\_\_\_ Score \_\_\_\_\_  
High Risk 3  
Medium Risk 2  
Low Risk 1

*Serving the Residents and Visitors of the Estes Valley with Superior Fire and Safety Services*